




DEPARTMENT OF BUILDING INSPECTION

City and County of San Francisco
1660 Mission Street, San Francisco, CA 94103

**Building Code Interpretation
Egress 002**

***Removing Second Exit from
Single Family Building***

Subject: Removing Second Exit from Existing R-3 Single Family Building	Date: May 13, 2008
San Francisco Building Code Section: 1019.2, #2	Code Year: 2007
Approved By: Isam Hasenin, Director, P.E., C.B.O.,	Signature: 
Question: May an existing single-family building have a second means of egress removed to have only one exit?	

Answer: Yes, an existing building containing a single dwelling unit may have a second exit, serving the dwelling unit, removed under the following conditions: <ul style="list-style-type: none">• the dwelling is no more than 3 stories above grade plane• the remaining exit from the dwelling meets the minimum exit requirements that were in effect when the dwelling was built or remodeled with permits• the dwelling fronts on a street or public way• the dwelling has a rear yard of at least four feet in depth.

This Code Application and Interpretation is subject to change at any time. To determine if this interpretation is still current, please call (415) 558-6205 or visit our website <http://www.sfgov.org/site/dbi>