


DEPARTMENT OF BUILDING INSPECTION
City and County of San Francisco
1660 Mission Street, San Francisco, CA 94103

Building Code Interpretation
Egress 007

R-3 Exit Access Travel Distance

Subject: Application of exit access travel distance requirements to R-3 buildings	Date: November 5, 2007
San Francisco Building Code Sections: 101A.9.1, 1016, Table 1016.1	Code Year: 2007
Approved By: Isam Hasenin, Director, P.E., C.B.O.	Signature: 
Question: Do the exit access travel distance requirements of Section 1016 apply to R-3 buildings?	

Answer: No, the exit access travel distance requirements of the 2007 San Francisco Building Code, Section 1016 do not apply to R-3 buildings
<small>This Code Application and Interpretation is subject to change at any time. To determine if this interpretation is still current, please call (415) 558-6205 or visit our website http://www.sfgov.org/site/dbi</small>