



INFORMATION SHEET

NO. FS-07

DATE : November 17, 2015
SUBJECT : Fire Safety
TITLE : **Elevator Lobbies in High-Rise Buildings**

PURPOSE : The purpose of this Information Sheet is to restrict movement of smoke and heat between floors through elevator doors and hoist-ways.

REFERENCES : CBC-2013 SECTION 713.14.1 Exceptions 2-8
CBC-2013 SECTION 1008.1.2 Exception 6
Exceptions listed in the above referenced codes shall not be applicable to high-rise buildings.

REQUIREMENTS :

Elevator lobbies in high-rise buildings shall be enclosed with 20-minute rated doors and shall be of the pivoted or side-hinged swinging type.

Lobbies that serve Fire Service Access Elevators shall be enclosed with 45-minute rated side-hinged swinging type doors.

Existing side-hinged swinging doors in high-rise elevator lobbies shall not be removed.

In existing non-conforming high-rise buildings where elevator lobbies are unenclosed, the installation of listed products complying with 2013 CBC 713.14.1 Exceptions 5 or 8 shall be acceptable.

Handwritten signature of Daniel de Cossio in blue ink.

Daniel de Cossio
Fire Marshal & Assistant Deputy Chief
San Francisco Fire Department

11/17/15

Date

Handwritten signature of Tom C. Hui in blue ink.

Tom C. Hui, S.E., C.B.O. *or*
Director
Department of Building Inspection

11/17/15

Date

This Information Sheet is subject to modification at any time. For the most current version, visit our website at <http://www.sfdbi.org>