

Plumbing Code Corrections

Chapter 10:

1. The following section was inadvertently left out of the 2007 Plumbing Code as a continuing requirement from the 2001 Plumbing Code. Reinsert this section as follows:

Section 1001.0 Traps Required

1001.5 Add the following new section:

1001.5 The building sewer or building drain shall have a building trap placed as near as possible to the curb line or immediately inside any subsidewalk basement wall under the sidewalk. Trap size shall be a minimum of 4 inches (101.6 mm).